



Architectural Testing

**ASTM C 1363-2011 THERMAL PERFORMANCE  
TEST REPORT**

**Rendered to:**

**DIAMOND DOOR PRODUCTS**

**SERIES/MODEL: Commercial Steel Door (Single)**

**TYPE: Swinging Door with Frame**

<b>Summary of Results</b>	
Standardized Thermal Transmittance (U-Factor)	0.47
Unit Size	40" x 86"

Reference must be made to Report No. C0369.01-116-46, dated 08/06/12 for complete test specimen description and data.

130 Derry Court  
York, PA 17406-8405  
phone: 717-764-7700  
fax: 717-764-4129  
www.archtest.com